## PT9232 (Extended Range)

#### Heavy Industrial • RS232 Communication

Linear Position/Velocity to 1700 inches (4300 cm) Stroke Range Options: 0-600 to 0-1700 inches **VLS Option To Prevent Free-Release Damage IP68 • NEMA 6 Protection** 

#### **GENERAL**

Full Stroke Range Option	0-600 to 0-1700 inches	
Electrical Interface		RS232
Format		HEX
Accuracy		± 0.10% full stroke
Repeatability		± 0.02% full stroke
Resolution		± 0.003% full stroke
Measuring Cable	staiı	nless steel or thermoplastic
Enclosure Material	powder-painted alum	ninum or 303 stainless steel
Sensor	plastic-hybr	rid precision potentiometer
Potentiometer Cycle Life	•	≥ 250,000 cycles
Maximum Retraction Ac	see ordering information	
Maximum Velocity	see ordering information	
Weight, Aluminum (Stair	14 lbs. (28 lbs.), max.	


#### **ELECTRICAL**

Input Voltage	922 VDC
Input Current	40 mA
Baud Rate	9600 (selectable to 38.4K)
Update Rate	32 msec

#### **ENVIRONMENTAL**

Enclosure	NEMA 4/4X/6, IP 67/68
Operating Temperature	-40° to 200°F (-40° to 90°C)
Vibration	up to 10 g to 2000 Hz maximum






The PT9232 delivers position feedback via RS232 serial communication to your data acquisition or controller system. The PT9232 sends a raw 16-bit count from 0000H to FFFFH. Additionally this device can be set to continuously send data or send data only when polled.

As the internal position sensing element is a precision potentiometer, this transducer maintains current accurate position even during power loss and does not need to be reset to a "home" position.

#### Output Signal:






20630 Plummer Street • Chatsworth, CA 91311 • Meas-Spec.com tel: 800.423.5483 • +1.818.701.2750 • fax: +1.818.701.2799

formally Celesco Transducer Products, Inc.

#### I/O Format

#### **Data Format**



#### **Data Frame**

#### 6 byte Hex string:

STX	CMD	B <sub>0</sub>	B <sub>1</sub>	B <sub>2</sub>	ETX	
 <b>STX</b> = 0x02	CMD = Con	nmand Code*	Bn - B2 =	Data Field*	<b>ETX</b> = 0x03	

-see below

Important! All communications to/from the transducer are in HEX!

#### **User Commands:**

		User Cor	nmand			Sensor F	Response	
Description	<cmd></cmd>	<b<sub>0&gt;</b<sub>	<b<sub>1&gt;</b<sub>	<b<sub>2&gt;</b<sub>	<cmd></cmd>	<b<sub>0&gt;</b<sub>	<b<sub>1&gt;</b<sub>	<b<sub>2&gt;</b<sub>
Get Sensor Info	0x05	0x00	0x00	0x00	0x05	version <sup>(4)</sup>	date <sup>(5)</sup>	date <sup>(5)</sup>
Get Serial Number	0x15	0x00	0x00	0x00	0x15	se	rial number <sup>(</sup>	3)
Start Continuous Data	0x25	0x00	0x00	0x00	0x25	0x00	0x00	0x00
Stop Continuous Data	0x35	0x00	0x00	0x00	0x35	0x00	0x00	0x00
Get Position Data	0x45	0x00	0x00	0x00	0x45	$CMC^{(1)}$	$CMC^{(1)}$	status <sup>(2)</sup>

#### (1)CMC - Current Measurement Count (Position)

The Current Measurement Count (CMC) is the output data that indicates the present position of the measuring cable.

The CMC is a 16-bit value that occupies the first two bytes ( $B_0$  and  $B_1$ ) of the data field.  $B_0$  is the MSB (most significant byte) and  $B_1$  is the LSB (least significant byte).

The CMC starts at 0000H with the measuring cable fully retracted and continues upward to the end of the stroke range stopping at FFFFH. This holds true for all ranges.

#### (2)Status

The status byte is used as a flag to indicate the validity of the position signal that the internal electronics receives from the potentiometer.

Flags are as follows: 0x00 = GREEN, 0x55 = YELLOW, 0xAA = RED

A "green" flag shows everything OK. A "yellow" or "red" flag indicates that the sensor has either been extended beyond its range or that there is a problem with the potentiometer.

#### (3)Serial Number

Each sensor has it's own unique serial number. This information can be retrieved by sending the sensor the "Get Serial Number" command.

The serial number is a 3 byte value from which ranges from 0 to 9999999 (decimal).

#### (4)Version

This is a single byte value (0-255 decimal) which indicates the currently installed firmware version of the sensor.

#### (5) Date

This is a 2 byte value showing the date of currently installed firmware. This value ranges from 01011 - 12319 (decimal). Format is MMDDY. While the month and day are expressed as two digit numbers the year is expressed in a single digit only.

Example: 08054 = August 5, 2004

#### **Baud Rate**

The baud rate can be set using switches **7** & **8** on the 8-pole DIP switch found on the rs232 controller board located inside the transducer.

DIP-7	DIP-8	baud rate
0	0	9600
1	0	19200
0	1	38400
1	1	9600





#### RS232 Controller Board and DIP Switch Location

# baud rate switches

internal dip switches & controller board to gain access to the controller board, remove four Allen-Head Screws and remove end cover


#### Outline Drawing






#### A DIMENSION

RANGE	inches [mm]
600	1.76 [44,7]
800	1.58 [40,1]
1000	1.98 [50,2]
1200	1.98 [50,2]
1500	1.86 [47,2]
1700	2.11 [53,6]





DIMENSIONS ARE IN INCHES [MM] tolerances are 0.03 IN. [0.5 MM] unless otherwise noted.

\* tolerance = +.005 -.001 [+.13 -.03] \*\* tolerance = +.005 -.005 [+.13 -.13]

#### Ordering Information:

### Model Number:



Sample Model Number:

PT9232 - 1200 - AL - FR - M6

range: 1200 inches
 enclosure aluminum
 cable exit: front (horizontal)

G electrical connection: front (nonzontal)
6-pin plastic connector

#### Full Stroke Range:


R order code:	600		800		1000		1200		1500		1700
full stroke range, min:	600 in.	:	800 in.	:	1000 in.	:	1200 in.	:	1500 in.	:	1700 in.
cable tension (±35%):	27 oz.	:	24 oz.	:	20 oz.	:	19 oz.	:	18 oz.	:	17 oz.
	.034-in. dia.	:	.019-in. dia.	:	.019-in. dia.	:	.019-in. dia.	:	.014-in. dia.		.014-in. dia.
measuring cable:	nylon-coated	:	nylon-coated		nylon-coated		nylon-coated		nylon-coated		nylon-coated
	stainless	:	stainless								


#### Ordering Information (cont.):

#### **Enclosure Material:**

A order code:	AL	SS
enclosure material:	powder-painted aluminum	303 stainless steel
max. acceleration:	1g	1g
max. velocitv:	60 inches/sec.	60 inches/sec.

#### Cable Exit:







version: 9.0 last updated: February 24, 2016